

- 4830

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No - 4830

Dated: 26/04/24

It is certified that an inspection team headed by Dr. N. Singh

(Name of Officers with designation) from ACMO

inspected the Deedar Singh Public Uchchatar Vidyalaya Kiraoli, Agra

(Name & Address of the school) on 25/04/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. W-190424-06 dated 23/04/24

of ITS Testing Laboratory (PHED Lab) certified that the

Deedar Singh Public Uchchatar (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31 March 2025

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

मुख्य चिकित्सा अधिकारी
Chief Medical Officer
Agra

To Deedar Singh Public Uchchatar Madhyamik
vidyalaya Jajau, Fatehpur Sikri Kiraoli Agra
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Usmani

Manager

Deedar Singh Public U.M. Vidyalay
Jajau, Agra

P. Nigam

Principal

Deedar Singh Public Uchchatar Madhyamik Vidyalay
Jajau, Agra



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itrlclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764



TEST REPORT

Water Sample Analysis

Report Code: W-190424-06

Issue Date: 22/04/2024

ISSUED TO: Deedar Singh Public Uchchatar Madhyamik Vidyalaya
Jajau, Fatehpur Sikri, Kiraoli, Agra- 283110

SAMPLING & ANALYSIS DATA

Sample Description : RO Water sample
Sample Drawn On : 19/04/2024
Sample Drawn By : Mr. Amit Sharma (ITS Representative)
Sampling Plan & Procedure : IS:17614 (Part-1) :2021
Sample Quantity : 2.0 Liter in Pet Bottle & 500ml in Sterilized Glass Bottle
Sample Received On : 19/04/2024
Analysis Duration : 19/04/2024 To 22/04/2024

TEST RESULTS

Chemical Analysis						
S. No.	Parameter	Test Method	Results	Units	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH	IS:3025(Part-11)	6.87	-	6.5 - 8.5	-
2.	Colour	IS:3025(Part-4)	<5.0	Hazen	5	15
3.	Turbidity	IS:3025(Part-10)	<1.0	NTU	1	5
4.	Total Hardness (as CaCO ₃)	IS:3025(Part-21)	42.0	mg/l	200	600
5.	Chloride(as Cl)	IS:3025(Part-32)	46.0	mg/l	250	1000
6.	Calcium (as Ca)	IS: 3025 (P- 40)	8.4	mg/l	75	200
7.	Iron (as Fe)	IS:3025(Part-53)	<0.05	mg/l	1.0	-
8.	Nitrate (as NO ₃)	IS: 3025 (P- 34)	<1.0	mg/l	45	No Relaxation
9.	Total Dissolved Solid	IS:3025(Part-16)	146	mg/l	500	2000
10.	Alkalinity (as CaCO ₃)	IS: 3025 (P- 23)	50.0	mg/l	200	600
11.	Fluoride (as F)	IS: 3025 (P- 60)	<0.1	mg/l	1.0	1.5
12.	Sulphate (as SO ₄)	IS:3025 (P-24)	<1.0	mg/l	200	400
13.	Magnesium (as Mg)	IS:3025 (P-46)	5.10	mg/l	30	100

Microbiological Analysis

RESULTS

S. No.	Parameter	Test Method	Results	Required as per IS-10500:2018
1.	Escherichia coli	IS-15185:2016	Absent	Absent/100ml
2.	Coliform Bacteria	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meet as per IS-10500:2018 specification.
Hence water is fit for Drinking purpose.

Authorized Signatory
(Microbiologist)

Manager

Deedar Singh Public U.M. Vidyalaya
Jajau, Agra

Authorized Signatory
(Chemical Analyst)

Principal

Deedar Singh Public Uchchatar
Jajau, Agra

Terms & Conditions

1. Test reports are valid only for the samples received at our laboratory. 2. Samples will be destroyed as per quality policy.
3. Any complaint or dispute should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to the invoiced amount.

